

# ADDENDUM NUMBER 1

ISSUED: March 16, 2020

**WESTERN VIRGINIA WATER AUTHORITY**  
**Painting RC IT Water Storage Tank Tank**  
**Project 2020-T-1**

---

To Bidders:

This Addendum is hereby made a part of the Contract Documents on which all bids shall be based. Bidders shall note the following changes, additions, and/or clarifications and submit bids accordingly. Bidders shall acknowledge receipt of this Addendum in the appropriate space on the bid form.

This Addendum consists of one (1) page(s) and one (2) attachment(s) as follows:

- Pre-Bid Conference Meeting Change, Agenda with questions from email or phone.
- 

**ITEM 1 Change: The Brebid meeting is not mandatory, and is canceled.**

Questions or comments should be addressed to Scott Agner by phone or email prior to March 27, 2020. **A second addendum will be issued on March 30, 2020 with any additional questions and clarification.**

ITEM 2 Attached agenda and comments.

# AGENDA

## Painting of RCIT Water Storage Tank

1. ~~Make sure that you sign the attendance List with the correct name of the company that will be submitting the bid. **Submittals from companies not listed on the attendance list will not be accepted.**~~
2. Submittals not following the "Instructions to Bidders" will not be accepted. Please note the new address to which the bid forms are to be returned. **1502 Brownlee Ave. S.E. Roanoke VA, 24014**
3. A copy of the minutes of this meeting, ~~the sign-in sheet~~, and any addendum will be included in Addendum #1 and posted on our website by Monday.
4. The color of the tank will be Light Blue PW3 (Sherwin Williams), or Ice Water 30 BL (Tnemec).
5. On page 5 section B. Exterior Tank Coating Systems; should be changed to read "Spot Prime Coat (for SP3 prepared areas): Immediately after surface preparation and before any rusting occurs, apply one coat of Sherwin-Williams Macropoxy 646 PW or Tnemec Series 27 Typoxy overlapping onto existing coating approximately two inches (2") in all directions. This coating shall be applied at a dry film thickness of 2.5 to 4.0 mils. If flash rust occurs prior to priming, the areas must be re-prepared prior to primer application."
6. Attached is a copy of the drawing of the RCIT Tank
7. Questions ask by phone or email
  - Q: The project time is 90 days, what is the start date? Is there a date it must be completed?
  - A: The notice to proceed could be issued as soon after the contract is signed as you request. October 1, 2020 is as late as we can allow.
8. The paint manufacturer to be used needs to be declared prior to the pre-construction meeting to allow a representative to be present.
9. Any other questions?

## Additional Questions from Meetings

Q: Are water and Power available on site?

A: 115 VAC power is available, Water is available but will have low pressure.

